Records of Tests of Fire Warning (Alarm) System

DATE	SYSTEM CHECKED BY	FREQUENCY OF TEST I.E. WEEKLY, 6 MONTHLY ETC.	REMARKS: (INCLUDE CALL POINT ID, ZONE NO. Etc)
15/08/23	*G. Sandieson*	*Quarterly*	*Landing Battery replaced* *Wired interconnect verified*
02/12/23	*G. Sandieson*	*-*	*Interconnected Smoke Alarms Installed and Tested*
01/04/24	*G. Sandieson*	*Tested*	*Tested Hall and Landing Alarms*
09/09/24	*G. Sandieson*	*Tested*	*Tested Hall and Landing Alarms*
06/02/24	*G. Sandieson*	*Tested*	*Successful Test*