**Periodic Inspection of Escape Routes** 

DATE	INSPECTED BY	FAULTS FOUND	ACTION
10/08/23	G. Sandieson	Potential to lock main door with key	Install Thumb Lock in Main Exit Door
01/12/23	G. Sandieson	None	Thumb Lock Installed for Fast Exit
01/04/24	G. Sandieson	None - lock tested & passages clear	None