Periodic Inspection of Escape Routes

DATE	INSPECTED BY	FAULTS FOUND	ACTION
10/08/23	*G. Sandieson*	*Potential to lock main door with key*	*Install Thumb Lock in Door*
01/12/23	*G. Sandieson*	*None*	*Thumb Lock Installed for Fast Exit*
01/04/24	*G. Sandieson*	*None - lock tested & passages clear*	*None*
06/02/25	*G. Sandieson*	*None - lock tested & passages clear*	*None*